



**City of Wilton Manors**  
Finance Department  
2020 Wilton Drive  
Wilton Manors, FL 33305

Phone (954) 390-2171  
Fax (954)390-2199  
www.wiltonmanors.com

## **Addendum No. 1**

**RFP for Diesel Generator Replacement**  
**Addendum Release Date June 09, 2022**

ITB # 2022-04

ITB Due Date/Time: August 09, 2022, 2:30 p.m. Eastern Standard Time

Submit To: City Clerk  
City of Wilton Manors  
2020 Wilton Drive  
Wilton Manors, Florida 33305

The purpose of this Addendum is to answer questions received from potential proposers. These are questions that were received prior to the published deadline for questions of June 06, 2022.

**IMPORTANT NOTE** – the following is added to ITB # 2022-04. It is the Proposer's responsibility to use the revised information when preparing the response.

1. Q: The city has listed model numbers and or component part number for a Kohler generator and transfer switch, will the city accept generators manufactured by Blue Star Power Systems and the transfer switches manufactured by ASCO?  
**A: Yes, the City has no preference on brand**
  
2. Q: What is the budget for each project?  
**A: Fire Station 16 – \$80,000.00**  
**A: Hagen Park – \$65,000**
  
3. Q: Will the fire station require a portable standby unit with MTS while the unit and transfer switch are being replaced?  
**A: Yes**
  
4. Q: Does the City have engineer drawings & elevation certificates for each location or will it be the contractors' responsibility to get site elevation certificates and drawings for permitting?  
**A: To be answered in Addendum No. 2**
  
5. Q: Do existing generator slab elevations meet new Broward county 100-year flood elevations? If not, slabs must be elevated.  
**A: To be answered in Addendum No. 2**
  
6. Q: Hagen Park generator request is for 180kw @ 277/480 voltage however, at the site visit, observed that ATS voltage is 120/208 volt. Is the city planning to change to 277/480 voltage?  
**A: To be answered in Addendum No. 2**



**City of Wilton Manors**  
Finance Department  
2020 Wilton Drive  
Wilton Manors, FL 33305

Phone (954) 390-2171  
Fax (954)390-2199  
www.wiltonmanors.com

7. Q: Is the contractor responsible for the initial fill for the start-up & load bank?  
**A: Yes**
  
8. Q: Bollards do not meet code at the Fire Station site are they to be replaced by contractor?  
**A: Yes**
  
9. Q: Is an emergency stop button required for the scope of work?  
**A: Yes**
  
10. Q: Can the Bid Opening date be moved back?  
**A: Yes, New Bid Opening Date is August 09<sup>th</sup>, 2022, 2:30 p.m.**
  
11. Q: Is there going to be an Addendum No. 2.  
**A: Yes, Addendum No. 2 will be posted by July 21<sup>st</sup>, 2022.**

**End of Addendum # 1**